

Report Date: 2020-08-27

Report Number:
200529063GZU-001



Test Report Sample Information: **Conformity declaration**

| | |
|---------------------------------|------------------------------|
| Product: | Stainless steel lever handle |
| Trade Mark: | D4e (Design4Excellence) |
| Model and / Or type Reference : | 931.912 series |
| Importer: | XXXX |
| Sample Id: | S200529063 - 001~022 |
| Date of receipt of test item: | 2020-05-29 and 2020-07-27 |
| Situation of receipt samples: | Received in good condition |
| Date(s) of performance of test: | 2020-06-04 ~ 2020-08-13 |

Testing information

Standard: EN 1906: 2012

Ratings

| | | | | | | | |
|-----|---|---|---|---|---|---|---|
| 3/4 | 7 | — | — | 0 | 3 | 0 | B |
|-----|---|---|---|---|---|---|---|

Classification of Installation and Use High frequency of use on doors which are subject to frequent violent usage; high frequency of use by public or others with little incentive to exercise care and with a high chance of misuse

Testing Laboratory Name: Intertek Testing Services Shenzhen Ltd.
Guangzhou Branch

Adress: Room 4103 & 4203, No. 63, Punan Road,
Huangpu District,
Guangzhou, China

Possible Test Case Verdicts

Test Case does not apply to the Test object: N/A
 Test object does meet the requirement: P (pass)
 Test object does not meet the requirement: F (Fail)

Conclusion

The submitted samples COMPLIED with all applicable clauses of EN 1906:2012 for the ratings. Item 5.8 was compliant after retest with second time received sample.

